

Accident PreventionDate submitted: **Oct-16-25 13:27:44**

Lodge: **Fort Pierce #1520 (SEC)**
Report Year: **2025**
Report Period: **Period 2**
Lodge Chair: **Kevin Eberle**
Report Submitted by: **Kevin Eberle / keberle157@comcast.net**

Is there information to report for this period? **Yes**

Accident Summary

Number of Accidents/Incidents this Quarter: **0**
Description of Each (Type, Location, Resolution): **None**
Were Incidents Reported to Gallagher Bassett?: **No**

Inspection Summary

Monthly Safety Inspections Completed (Yes/No per Month): **Yes**
Electrical panel in utility off Ballroom was blocked with boxes. Boxes were removed from area.
Summary of Issues Found and Actions Taken: **Light cover in Lodge room was hanging from side posing a hazard if it fell. Cover was reattached and secured.**
Globe on light on emergency exit ramp from Ballroom has a broken globe. Plan has been developed to replace in the near future.
Date of Most Recent Lodge Safety Checklist: **October 11, 2025**

Preventative Measures

Trainings Conducted (Dates, Type, Attendance):
Corrective Actions Implemented: **Annual fire alarm inspection completed on 10/10/25**

General Compliance

Alcohol Service Policy Reviewed/Updated (Yes/No): **Yes**
Kitchen/Equipment Safety Measures Enforced (Yes/No): **Yes**

Trainings Conducted (Dates,
Type, Attendance):

Receipts / Images (if applicable)

Comments / Requests

Support or Resources Needed:

Corrective Actions

Implemented: